



## Appendix C Noise Monitoring Data Trending


# Impact Noise Monitoring Results during Day Time (0700 - 1900 hours)



# Additional Impact Noise Monitoring Results during Evening Time (1900 - 2300 hours)



# Additional Impact Noise Monitoring Results during Night Time (2300 - 0700 hours)



**Summary of the Construction Activities Undertaken during the Reporting Period**

<b>Location of works</b>	<b>Construction activities undertaken</b>	<b>Remarks on progress</b>
Reclamation area	<ul style="list-style-type: none"> <li>• Foundation works (including Driven H Pile and Socketed H Pile)</li> <li>• Pile cap construction</li> <li>• Structural steel work</li> <li>• Superstructure construction</li> </ul>	<ul style="list-style-type: none"> <li>• Completed</li> <li>• On-going</li> <li>• On-going</li> <li>• On-going</li> </ul>
Seawall portion	<ul style="list-style-type: none"> <li>• Caisson extension works, from +3mPD to +6mPD, at Seawall A and B</li> <li>• Construction of wave wall along the vertical seawall above +3mPD</li> </ul>	<ul style="list-style-type: none"> <li>• On-going</li> <li>• On-going</li> </ul>

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 1 (M1 / N\_S1)

Monitoring date: 03, 12, 18, 24, 30 October 2023 (Daytime)

03&04, 12&13, 18&19, 24&25 and 30&31 October 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
03 Oct 2023	14:12	-	14:42	Sunny	64.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
03 Oct 2023	19:12	-	19:17	Fine	50.8	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	20:32	-	20:37		52.1		
	21:32	-	21:37		52.7		
04 Oct 2023	1:22	-	1:27	Fine	51.4	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	3:17	-	3:22		48.0		
	5:12	-	5:17		47.0		
12 Oct 2023	14:21	-	14:51	Sunny	57.6	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
12 Oct 2023	19:06	-	19:11	Fine	48.2	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	20:11	-	20:16		49.1		
	21:16	-	21:21		46.1		
13 Oct 2023	1:11	-	1:16	Fine	46.3	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	3:11	-	3:16		46.9		
	5:06	-	5:11		44.8		
18 Oct 2023	14:51	-	15:21	Fine	56.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
18 Oct 2023	19:06	-	19:11	Fine	57.8	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	20:01	-	20:06		59.3		
	21:11	-	21:16		54.8		
19 Oct 2023	1:11	-	1:16	Fine	53.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	3:26	-	3:31		50.1		
	5:21	-	5:26		49.7		
24 Oct 2023	14:17	-	14:47	Sunny	57.4	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
24 Oct 2023	19:22	-	19:27	Fine	47.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	20:27	-	20:32		45.8		
	21:27	-	21:32		42.5		
25 Oct 2023	1:22	-	1:27	Fine	46.4	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	3:02	-	3:07		41.7		
	5:12	-	5:17		45.1		

<b>Date</b>	<b>Start time</b>		<b>End time</b>	<b>Weather</b>	<b>L<sub>eq 30min</sub> dB(A) / L<sub>eq 5min</sub> dB(A)</b>	<b>Sound Level Meter Used</b>	<b>Calibrator Used</b>
30 Oct 2023	14:03	-	14:33	Sunny	57.7	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
30 Oct 2023	19:13	-	19:18	Fine	51.3	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	20:13	-	20:18		48.0		
	21:28	-	21:33		47.0		
31 Oct 2023	1:18	-	1:23	Fine	40.7	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124528)
	3:23	-	3:28		39.6		
	5:23	-	5:28		40.9		

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 1 (M1 / N\_S1)

Monitoring date: 10, 13, 20, 29 November 2023 (Daytime)

10&11, 13&14, 20&21 and 29&30 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
10 Nov 2023	13:33	-	14:03	Sunny	57.8	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
10 Nov 2023	19:08	-	19:13	Fine	51.8	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:08	-	20:13		53.9		
	21:08	-	21:13		52.3		
11 Nov 2023	1:08	-	1:13	Fine	46.6	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:08	-	3:13		45.0		
	5:08	-	5:13		45.1		
13 Nov 2023	13:42	-	14:12	Sunny	56.3	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
13 Nov 2023	19:12	-	19:17	Fine	47.5	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:12	-	20:17		53.9		
	21:07	-	21:12		45.3		
14 Nov 2023	1:07	-	1:12	Fine	44.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:07	-	3:12		43.2		
	5:12	-	5:17		44.3		
20 Nov 2023	13:57	-	14:27	Sunny	63.2	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
20 Nov 2023	19:12	-	19:17	Fine	47.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:27	-	20:32		46.1		
	21:17	-	21:22		45.3		
21 Nov 2023	1:17	-	1:22	Fine	41.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:17	-	3:22		41.1		
	5:17	-	5:22		40.2		
29 Nov 2023	13:50	-	14:20	Cloudy	60.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
29 Nov 2023	19:10	-	19:15	Fine	50.4	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:25	-	20:30		43.0		
	21:30	-	21:35		42.7		
30 Nov 2023	1:10	-	1:15	Fine	41.2	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:15	-	3:20		42.2		
	5:20	-	5:25		40.2		



Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 1 (M1 / N\_S1)

Monitoring date: 05, 11, 18, 27 December 2023 (Daytime)

05&06, 11&12, 18&19 and 27&28 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
05 Dec 2023	13:45	-	14:15	Sunny	62.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
05 Dec 2023	19:20	-	19:25	Fine	53.3	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:10	-	20:15		44.4		
	21:30	-	21:35		43.6		
06 Dec 2023	1:20	-	1:25	Fine	41.6	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:20	-	3:25		38.2		
	5:05	-	5:10		39.2		
11 Dec 2023	13:47	-	14:17	Sunny	56.2	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
11 Dec 2023	19:17	-	19:22	Fine	52.0	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:27	-	20:32		46.6		
	21:32	-	21:37		45.3		
12 Dec 2023	1:27	-	1:32	Fine	42.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:07	-	3:12		42.3		
	5:07	-	5:12		42.4		
18 Dec 2023	13:17	-	13:47	Fine	56.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
18 Dec 2023	19:12	-	19:17	Fine	45.5	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:17	-	20:22		44.2		
	21:17	-	21:22		44.5		
19 Dec 2023	1:42	-	1:47	Fine	40.1	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:22	-	3:27		38.6		
	5:12	-	5:17		40.8		
27 Dec 2023	13:47	-	14:17	Fine	59.2	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
27 Dec 2023	19:17	-	19:22	Fine	49.9	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	20:22	-	20:27		50.1		
	21:12	-	21:17		45.4		
28 Dec 2023	1:22	-	1:27	Fine	42.3	SVAN 971 (Serial No. 96062)	Rion NC-75 (No.35124527)
	3:27	-	3:32		39.7		
	5:12	-	5:17		38.8		

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 2 (M2 / N\_S2)

Monitoring date: 03, 12, 18, 24, 30 October 2023 (Daytime)

03&04, 12&13, 18&19, 24&25 and 30&31 October 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
03 Oct 2023	14:13	-	14:43	Sunny	63.0	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
03 Oct 2023	19:18	-	19:23	Fine	50.3	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
	20:13	-	20:18		52.8		
	21:18	-	21:23		52.8		
04 Oct 2023	1:18	-	1:23	Fine	50.6	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
	3:23	-	3:28		49.1		
	5:18	-	5:23		47.7		
12 Oct 2023	14:29	-	14:59	Sunny	57.7 <sup>[1]</sup>	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
12 Oct 2023	19:09	-	19:14	Fine	49.7 <sup>[1]</sup>	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
	20:29	-	20:34		51.4 <sup>[1]</sup>		
	21:14	-	21:19		51.2 <sup>[1]</sup>		
13 Oct 2023	1:19	-	1:24	Fine	51.7 <sup>[1]</sup>	SVAN 971 (Serial No. C119577)	Rion NC-75 (No.35124528)
	3:09	-	3:14		51.1 <sup>[1]</sup>		
	5:14	-	5:19		49.2 <sup>[1]</sup>		
18 Oct 2023	15:01	-	15:31	Fine	60.1	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
18 Oct 2023	19:26	-	19:31	Fine	56.4	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	20:06	-	20:11		58.7		
	21:21	-	21:26		53.3		
19 Oct 2023	1:26	-	1:31	Fine	49.5	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	3:26	-	3:31		48.8		
	5:16	-	5:21		49.3		
24 Oct 2023	14:00	-	14:30	Sunny	53.4	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
24 Oct 2023	19:10	-	19:15	Fine	48.6	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	20:25	-	20:30		49.2		
	21:15	-	21:20		53.3		
25 Oct 2023	1:35	-	1:40	Fine	47.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	3:20	-	3:25		41.4		
	5:10	-	5:15		42.3		

Date	Start time		End time	Weather	$L_{eq\ 30min\ dB(A)} / L_{eq\ 5min\ dB(A)}$	Sound Level Meter Used	Calibrator Used
30 Oct 2023	13:45	-	14:15	Sunny	55.8	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
30 Oct 2023	19:15	-	19:20	Fine	51.6	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	20:20	-	20:25		51.5		
	21:20	-	21:25		49.6		
31 Oct 2023	1:20	-	1:25	Fine	39.1	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	3:10	-	3:15		40.7		
	5:25	-	5:30		41.6		

Note:

- [1] Noise meter SVAN 971 (Serial No. C119577) was deployed for impact noise monitoring on 12/10/2023 at M2 after its calibration certificate was expired on 10/10/2023, data collected on 12/10/2023 at M2 is for reference only.

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 2 (M2 / N\_S2)

Monitoring date: 10, 13, 20, 29 November 2023 (Daytime)

10&11, 13&14, 20&21 and 29&30 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
10 Nov 2023	13:39	-	14:09	Sunny	57.2	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
10 Nov 2023	19:09	-	19:14	Fine	51.6	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:09	-	20:14		49.3		
	21:09	-	21:14		48.0		
11 Nov 2023	1:09	-	1:14	Fine	47.0	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:09	-	3:14		45.6		
	5:09	-	5:14		47.3		
13 Nov 2023	13:21	-	13:51	Sunny	56.6	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
13 Nov 2023	19:16	-	19:21	Fine	49.9	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:06	-	20:11		49.7		
	21:01	-	21:06		49.6		
14 Nov 2023	1:06	-	1:11	Fine	46.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:06	-	3:11		49.0		
	5:31	-	5:36		48.0		
20 Nov 2023	13:54	-	14:24	Sunny	62.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
20 Nov 2023	19:14	-	19:19	Fine	48.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:04	-	20:09		53.2		
	21:19	-	21:24		49.3		
21 Nov 2023	1:14	-	1:19	Fine	45.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:14	-	3:19		45.4		
	5:24	-	5:29		45.2		
29 Nov 2023	13:32	-	14:02	Cloudy	57.8	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
29 Nov 2023	19:07	-	19:12	Fine	51.0	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:12	-	20:17		49.6		
	21:17	-	21:22		47.7		
30 Nov 2023	1:12	-	1:17	Fine	44.4	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:07	-	3:12		43.3		
	5:02	-	5:07		43.5		

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 2 (M2 / N\_S2)

Monitoring date: 05, 11, 18, 27 December 2023 (Daytime)

05&06, 11&12, 18&19 and 27&28 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring Data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
05 Dec 2023	13:47	-	14:17	Sunny	64.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
05 Dec 2023	19:12	-	19:17	Fine	48.7	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:12	-	20:17		47.1		
	21:17	-	21:22		47.0		
06 Dec 2023	1:27	-	1:32	Fine	44.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:22	-	3:27		43.3		
	5:07	-	5:12		44.0		
11 Dec 2023	13:30	-	14:00	Sunny	58.4	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
11 Dec 2023	19:15	-	19:20	Fine	52.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:10	-	20:15		49.9		
	21:15	-	21:20		49.6		
12 Dec 2023	1:25	-	1:30	Fine	45.4	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:20	-	3:25		45.0		
	5:05	-	5:10		45.8		
18 Dec 2023	13:32	-	14:02	Fine	55.1	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
18 Dec 2023	19:12	-	19:17	Fine	47.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:17	-	20:22		47.0		
	21:12	-	21:17		46.2		
19 Dec 2023	1:42	-	1:47	Fine	44.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:27	-	3:32		44.7		
	5:17	-	5:22		44.1		
27 Dec 2023	13:57	-	14:27	Fine	56.3	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
27 Dec 2023	19:22	-	19:27	Fine	49.9	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	20:22	-	20:27		49.6		
	21:17	-	21:22		46.4		
28 Dec 2023	1:27	-	1:32	Fine	44.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124527)
	3:27	-	3:32		44.3		
	5:12	-	5:17		44.3		

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 3 (M3 / N\_S3)

Monitoring date: 03, 12, 18, 24, 31 October 2023 (Daytime)

03&04, 12&13, 18&19, 24&25 and 31 October & 01 November 2023  
(Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Air-conditioner

Noise Monitoring data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
03 Oct 2023	14:09	-	14:39	Sunny	60.3	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
03 Oct 2023	19:09	-	19:14	Fine	55.5	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
	20:04	-	20:09		56.4		
	21:34	-	21:39		54.7		
04 Oct 2023	1:04	-	1:09	Fine	55.5	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
	3:34	-	3:39		55.0		
	5:19	-	5:24		52.4		
12 Oct 2023	14:15	-	14:45	Sunny	55.5	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
12 Oct 2023	19:05	-	19:10	Fine	56.0	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
	20:10	-	20:15		51.1		
	21:25	-	21:30		50.0		
13 Oct 2023	1:10	-	1:15	Fine	55.5	SVAN 971 (Serial No. C132261)	Rion NC-75 (No.35124528)
	3:30	-	3:35		54.0		
	5:25	-	5:30		44.6		
18 Oct 2023	14:48	-	15:18	Fine	58.8	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
18 Oct 2023	19:28	-	19:33	Fine	57.4	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	20:48	-	20:53		61.1		
	21:43	-	21:48		59.9		
19 Oct 2023	1:13	-	1:18	Fine	62.5	SVAN 971 (Serial No. 103449)	Rion NC-75 (No.35124528)
	2:58	-	3:03		62.7		
	5:03	-	5:08		62.0		
24 Oct 2023	14:08	-	14:38	Sunny	56.0	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
24 Oct 2023	19:03	-	19:08	Fine	56.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	20:43	-	20:48		49.6		
	21:28	-	21:33		44.8		
25 Oct 2023	1:33	-	1:38	Fine	41.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	3:18	-	3:23		41.2		
	5:18	-	5:23		42.2		

<b>Date</b>	<b>Start time</b>		<b>End time</b>	<b>Weather</b>	<b>L<sub>eq 30min</sub> dB(A) / L<sub>eq 5min</sub> dB(A)</b>	<b>Sound Level Meter Used</b>	<b>Calibrator Used</b>
31 Oct 2023	14:03	-	14:33	Sunny	58.0	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
31 Oct 2023	19:08	-	19:13	Fine	45.2	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	20:18	-	20:23		45.7		
	21:18	-	21:23		44.2		
01 Nov 2023	1:18	-	1:23	Fine	43.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124528)
	3:28	-	3:33		40.9		
	5:23	-	5:28		41.2		

Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 3 (M3 / N\_S3)

Monitoring date: 10, 13, 20, 29 November 2023 (Daytime)  
10&11, 13&14, 20&21 and 29&30 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Construction works of air quality monitoring station

Noise Monitoring data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
10 Nov 2023	16:30	-	17:00	Sunny	54.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
10 Nov 2023	19:10	-	19:15	Fine	52.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:05	-	20:10		48.4		
	21:15	-	21:20		49.6		
11 Nov 2023	1:10	-	1:15	Fine	46.0	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:20	-	3:25		48.3		
	5:05	-	5:10		46.6		
13 Nov 2023	16:05	-	16:35	Sunny	57.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
13 Nov 2023	19:10	-	19:15	Fine	44.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:05	-	20:10		44.3		
	21:25	-	21:30		45.8		
14 Nov 2023	1:20	-	1:25	Fine	43.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:20	-	3:25		43.8		
	5:20	-	5:25		44.0		
20 Nov 2023	16:46	-	17:16	Sunny	54.8	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
20 Nov 2023	19:21	-	19:26	Fine	47.9	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:11	-	20:16		48.4		
	21:31	-	21:36		42.6		
21 Nov 2023	1:06	-	1:11	Fine	46.0	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:21	-	3:26		40.2		
	5:11	-	5:16		41.5		
29 Nov 2023	14:45	-	15:15	Cloudy	58.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
29 Nov 2023	19:10	-	19:15	Fine	45.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:15	-	20:20		47.1		
	21:20	-	21:25		44.3		
30 Nov 2023	1:15	-	1:20	Fine	42.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:10	-	3:15		41.8		
	5:15	-	5:20		43.6		



Location: Shek Kwu Chau Treatment & Rehabilitation Centre Hostel 3 (M3 / N\_S3)

Monitoring date: 05, 11, 18, 27 December 2023 (Daytime)

05&06, 11&12, 18&19 and 27&28 November 2023 (Evening & Night time)

Parameter :  $L_{eq\ 30min}$  (Daytime),  $L_{eq\ 5min}$  (Evening & Night time)

Noise source other than construction activities from the Project: Nil

Noise Monitoring data:

Date	Start time		End time	Weather	$L_{eq\ 30min}$ dB(A) / $L_{eq\ 5min}$ dB(A)	Sound Level Meter Used	Calibrator Used
05 Dec 2023	13:40	-	14:10	Sunny	62.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
05 Dec 2023	19:20	-	19:25	Fine	44.5	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:40	-	20:45		45.4		
	21:15	-	21:20		38.3		
06 Dec 2023	1:30	-	1:35	Fine	38.1	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:25	-	3:30		35.1		
	5:15	-	5:20		39.1		
11 Dec 2023	13:41	-	14:11	Sunny	61.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
11 Dec 2023	19:16	-	19:21	Fine	54.3	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:11	-	20:16		47.3		
	21:11	-	21:16		53.1		
12 Dec 2023	1:06	-	1:11	Fine	44.3	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:21	-	3:26		43.1		
	5:11	-	5:16		43.9		
18 Dec 2023	13:10	-	13:40	Fine	55.5	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
18 Dec 2023	19:10	-	19:15	Fine	44.7	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:20	-	20:25		47.7		
	21:15	-	21:20		45.0		
19 Dec 2023	1:40	-	1:45	Fine	40.2	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:30	-	3:35		39.9		
	5:10	-	5:15		38.9		
27 Dec 2023	13:47	-	14:17	Fine	56.9	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
27 Dec 2023	19:17	-	19:22	Fine	42.6	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	20:17	-	20:22		45.1		
	21:17	-	21:22		41.9		
28 Dec 2023	1:27	-	1:32	Fine	38.5	SVAN 971 (Serial No. 96063)	Rion NC-75 (No.35124527)
	3:27	-	3:32		40.6		
	5:17	-	5:22		39.4		